

CONTRACT ADDENDUM NO. 1

WEST SOUND UTILITY DISTRICT

2016 Water Supply and Storage Improvements Project

Date of Issue: September 12, 2016

Date of Opening: September 28, 2016

Notice To All Planholders:

This Addendum No. 1, containing the following additions, is hereby made a part of the Plans and Contract Provisions (Contract Documents) for the above named project. It shall be attached to the Contract Provisions and shall be taken into consideration by the Bidders in submitting their bids.

CONTRACT PROVISIONS

Item No. 1: Instructions to Bidders

Add the following to Section II, Instructions to Bidders:

2-11 Award of Contract: The District intends to perform both the Well 1/5 site and Well 22 site projects and award to the lowest qualified bidder for the sum of both projects. However, the District reserves the right to award multiple contracts, remove work, eliminate a project, and/or not make an award. The District also reserves the right to reject all bids and/or waive any informality in the bidding.

Item No. 2: Roof Plates and Support Structure

REPLACE Part 1.3.I of Section 13205 of the CSI Specifications with the following:

The roof plates and support structure shall be completely seal welded on the interior and exterior.

Item No. 3: Column Base Plate

REPLACE Part 1.3.R of Section 13205 of the CSI Specifications with the following:

Tank columns shall be fabricated from steel pipe and sealed on both ends. The column base plate(s) shall be fabricated from steel plate and seal welded to the column. Steel tabs shall be welded to the floor on each side of the column base plate to keep the column and base plate from sliding.

Item No. 4: Seismic Group

REPLACE Part 1.4.A.1 of Section 13205 of the CSI Specifications with the following:

Seismic Use Group: II

Item No. 5: Manway

REPLACE Part 2.1.B of Section 13205 of the CSI Specifications with the following:

Shell Manways: Provide two (2) 30" diameter manways with self-positioning u-shaped gaskets. Manways shall open to exterior. Manways shall have provisions for locking. Stainless steel components inside the tank, if any, shall be electrically isolated from the tank.

ALL OTHER REQUIREMENTS OF THE CONTRACT DOCUMENTS REMAIN IN EFFECT



Michael R. Wilson
General Manager

Date: 9/12/16