

**WEST SOUND UTILITY DISTRICT  
RESOLUTION 749-18**

**A RESOLUTION OF THE BOARD OF COMMISSIONERS  
OF WEST SOUND UTILITY DISTRICT  
ACCEPTING THE WATER AND SEWER IMPROVEMENTS  
ST. VINCENT DE PAUL FACILITY PROJECT**

**WHEREAS**, West Sound Utility District (“District”) and Mr. Sean Jeu, St. Vincent de Paul Operations Director entered into development extension agreement on October 18, 2016, for the private developer water and sewer system extensions for the St. Vincent de Paul facility; and

**WHEREAS**, the water and sewer system improvements of this utility development project have been constructed by Mr. Sean Jeu, St. Vincent de Paul, in accordance with the standards of the District and approved by the District’s Operations staff; and

**WHEREAS**, the water and sewer systems to be conveyed to the District consist of the following: water system – 110’ of 1.5” poly ethylene water line, 97’ of 6” ductile iron main, 72’ of 4” ductile iron main, two (2) thrust blocks and valves; and sewer system – 60’ of 6” PVC SDR 35 sewer line with two (2) cleanouts.


**WHEREAS**, the water main system for a value of \$15,002 and sewer main system for a value of \$18,484 will be conveyed to the District upon the acceptance of the water and sewer system by the District’s Board of Commissioners; NOW, THEREFORE,


**THE BOARD OF COMMISSIONERS OF WEST SOUND UTILITY DISTRICT HEREBY RESOLVES:**


Section 1. West Sound Utility District accepts the water and sewer utility system extensions for the St. Vincent de Paul facility and hereby authorizes the District’s General Manager to sign the conveyance documents.

**APPROVED and ADOPTED** by the Board of Commissioners of West Sound Utility District at a regular scheduled meeting on June 18, 2018.

**WEST SOUND UTILITY DISTRICT**  
Kitsap County, Washington

  
\_\_\_\_\_  
Susan Way  
Chairperson

  
\_\_\_\_\_  
James J. Hart  
Vice Chairperson

  
\_\_\_\_\_  
Jerry Lundberg  
Secretary

**HENDERSON PARTNERS, LLC**  
11302 BURNHAM DR NW  
GIG HARBOR WA 98332  
253.851.5895 OFFICE  
253.851.5826 FAX



**Contractor Number HENDEPL992MQ**

**TO: West Sound Utilities**

**RE: Final Construction Costs**

West Sound Utilities, These are the final Construction costs for the Water, fireline and Sewer improvements for St. Vincent located at 2525 Bethel Ave, Port Orchard, WA.

Water: Construct 110 lf of 1.5inch poly ethylene pipe water line, 1 water meter placed behind the sidewalk on Mitchell st. **Final Construction cost is \$3,974. Three thousand nine hundred and seventy four dollars.**

Fire line: Construct 97 lf of 6 inch Ductile Iron class 52 from Tap on Mitchell into building. 72 lf of 4 inch Ductile Iron from building to FDC placed behind sidewalk on Mitchell st. 2 thrust blocks and valves. **Final Construction cost is \$11,028. Eleven thousand and twenty eight dollars.**

Sewer: 60 lf of 6 inch PVC SDR 35 sewer line with 2 cleanouts. **Final Construction cost is \$18,484. Eighteen Thousand four hundred and eighty four dollars.**